

Addendum # 2 Laundry Equipment P-Laundry072022

Answers to questions during walk through

1. For the service agreement, there are no collections involved for the vendor. **Answer: No collections involved**
Only service for a machine breakdown due to equipment failure. **Answer: Service agreement shall begin once the manufacturers Warranty has been exhausted. Parts shall be warrantied free of cost to the SHA for 3 years , labor warranty is a minimum of 90 days, after and SHA final acceptance. If the equipment is defective it shall be replaced, or no payment shall be made for the unit.**
2. For the service agreement, travel time is included in the price. **Answer: yes, No additional payment will be made for travel time or fuel.**
3. The SHA wants stainless steel braided hoses for the washers to be supplied by the vendor. **Answer: yes. Vendor shall supply and connect steel braided hoses for the washer's feed. Vendor will supply\install discharge hoses as recommended by the manufacturer.**
4. The SHA will connect the gas dryers, including the vent. Vendor to supply flexi-gas connections. **Answer: NO. The SHA will connect the gas to the (10) gas dryers,. Vendor to supply flexible flexi-gas connections recommended by manufacturer and flexible vent hose. All product shall be new not used or recycled.**
5. The SHA wants 6-inch bases, not 8-inch bases. **Answer: Yes. Base size has changed to 6-inch bases. (Not 8-inch)**
6. At Properzi Manor, 13-25 Warren, the SHA will remove the base under the current equipment. The SHA wants tracks and bases at this location for both washers and dryers. **Answer: YES, tracks and bases at this location for both washers and dryers.**
7. Hagan Manor, 268 Washington Street the SHA will remove the base under the current equipment. The SHA wants tracks and bases at this location for both washers and dryers. **Answer: YES. Tracks and bases at this location for both washers and dryers.**
8. Properzi Manor 13-25 Warren Ave exhaust of dryers shall be reused and not discarded as they are not 100% flexible. **Answer: Yes, Vendor shall vacuum the existing 6'-8' portion of exhaust before connecting. If flexible connection is needed the vendor shall provide. (The intent is to install new equipment in a clean and safe exhaust) If the non-flexible portion of the exhaust is not safe the vendor shall communicate to the SHA purchasing department that it needs to be replaced by the SHA.**
9. At 32 and 125 Jaques street, the SHA will remove the base under the dryers. The SHA wants tracking and bases at this location for both washers and dryers. **Answer: Yes, Vendor shall vacuum the 4'-6' portion of exhaust before connecting. If flexible connection is needed the vendor shall provide. (The intent is to install new equipment in a clean and safe exhaust) If the non-flexible portion of the exhaust is not safe the vendor shall communicate to the SHA purchasing department that it needs to be replaced by the SHA. Tracks and bases at these locations for both washers and dryers.**